

**PACKANACK ELEMENTARY
190 OAKWOOD DRIVE**

Test Date - 8/22/16 & 9/22/16

KEY:

TNR: Testing Not Required
 ND: None Detected BS: Below DEP/EPA Standard
 DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

SAMPLE NUMBER	DESCRIPTION	TEST RESULTS	NOTES
L6436062-1	CLASSROOM 4 SINK	0.023	TNR/BS
L6479157-10	CLASSROOM 1 SINK	0.088	TNR/BS
L6436062-3	FOUNTAIN MAIN ENT UPPER	0.008	BS
L6436062-4	CLASSROOM 4 FOUNTAIN	0.120	BS
L6436062-5	LADIES ROOM MAIN ENT SINK 2	0.005	TNR/BS
L6436062-6	FOUNTAIN MAIN ENT LOWER	0.002	BS
L6436062-7	GYM FOUNTAIN UPPER	0.007	BS
L6436062-8	OFFICE SINK	0.003	BS
L6436062-9	CLASSROOM 2 SINK	0.012	TNR/BS
L6436062-10	CLASSROOM 3 SINK	0.006	TNR/BS
L6436062-11	GIRLS ROOM SINK 2	0.013	TNR/BS
L6436062-12	GIRLS ROOM SINK 3	0.028	TNR/BS
L6436062-13	LADIES ROOM MAIN ENT SINK 1	0.008	TNR/BS
L6479157-11	CLASSROOM 22 FOUNTAIN	0.028	BS
L6436062-15	CLASSROOM 27 FOUNTAIN	0.034	BS
L6436062-16	GIRLS ROOM SINK 4	0.004	TNR/BS
L6479157-9	CLASSROOM 1 FOUNTAIN	0.045	BS
L6436062-18	GIRLS ROOM SINK 1	0.005	TNR/BS
L6436062-19	CLASSROOM 2 FOUNTAIN	0.054	BS
L6436062-20	CLASSROOM 22 SINK	0.020	TNR/BS
L6479157-13	CLASSROOM 25 FOUNTAIN	ND	ND
L6436062-22	CLASSROOM 26 SINK	0.015	TNR/BS
L6436062-23	KITCHEN SINK ON WALL RIGHT	0.013	BS
L6436062-24	CLASSROOM 19 SINK	0.053	TNR/BS
L6436062-25	GYM FOUNTAIN LOWER	0.025	BS
L6436062-26	MENS ROOM MAIN ENT SINK RIGHT	0.004	TNR/BS
L6436062-27	MENS ROOM MAIN ENT SINK LEFT	0.008	TNR/BS
L6436062-28	LADIES ROOM MAIN ENT SINK 3	0.032	TNR/BS
L6436062-29	CLASSROOM 25 SINK	0.049	TNR/BS
L6436062-30	BOYS ROOM BY CAFETERIA	0.013	TNR/BS
L6436062-31	GIRLS ROOM BY CAFETERIA	0.063	TNR/BS
L6436062-32	KITCHEN SINK ON WALL LEFT	0.006	BS
L6436062-33	CLASSROOM 19 FOUNTAIN	0.098	BS
L6479157-12	CLASSROOM 26 FOUNTAIN	ND	ND
L6436062-35	CLASSROOM 23 SINK	0.005	TNR
L6479157-8	KITCHEN SINK BY COUNTER	NOT REQUIRED	REMOVED
L6479157-2	CLASSROOM 18 FOUNTAIN	NOT REQUIRED	REMOVED
L6436062-38	CLASSROOM 20 SINK	0.007	TNR/BS

PACKANACK ELEMENTARY

190 OAKWOOD DRIVE

Test Date - 8/22/16 & 9/22/16

KEY:

TNR: Testing Not Required

ND: None Detected BS: Below DEP/EPA Standard

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

L6436062-39	SLOP SINK BY CAFETERIA	0.008	TNR/BS
L6436062-40	CAFETERIA SINK	0.020	TNR/BS
L6436062-41	CAFETERIA FOUNTAIN	0.030	TNR/BS
L6479157-5	CLASSROOM 27 SINK	ND	TNR
L6436062-43	CLASSROOM 14 FOUNTAIN	0.048	BS
L6436062-44	KITCHEN SINK ON ISLAND	0.011	BS
L6436062-45	CLASSROOM 24 SINK	0.033	TNR/BS
L6436062-46	CLASSROOM 24 FOUNTAIN	0.020	BS
L6436062-47	CLASSROOM 18 SINK	0.035	TNR/BS
L6436062-48	CLASSROOM 20 FOUNTAIN	0.004	BS
L6436062-49	BOYS ROOM BY ROOM 7 SINK 3	0.028	TNR/BS
L6436062-50	FOUNTAIN BY ART ROOM	0.018	BS
L6436062-51	CLASSROOM 5 SINK	0.039	TNR/BS
L6479157-7	CLASSROOM 17 FOUNTAIN	0.065	BS
L6436062-53	CLASSROOM 17 SINK	0.030	TNR/BS
L6436062-54	CLASSROOM 8 SINK	0.012	TNR/BS
L6436062-55	TEACHERS ROOM SINK	0.024	BS
L6436062-56	CLASSROOM 14 SINK	0.055	TNR/BS
L6436062-57	CLASSROOM 12 SINK	0.005	TNR/BS
L6436062-58	FOUNTAIN 2 BY MEDIA CENTER	0.034	BS
L6436062-59	CLASSROOM 18 SINK	0.013	TNR/BS
L6436062-60	CLASSROOM 13 FOUNTAIN	0.025	BS
L6436062-61	MEDIA ROOM SINK	0.026	BS
L6436062-62	CLASSROOM 6 FOUNTAIN	0.112	BS
L6436062-63	BOYS ROOM BY CLASSROOM 7 SINK 2	0.018	TNR/BS
L6436062-64	CLASSROOM 6 SINK	0.027	TNR/BS
L6436062-65	CLASSROOM 12 FOUNTAIN	0.006	BS
L6479157-6	CLASSROOM 7 SINK	STORAGE RM.	REMOVED
L6479157-1	ART ROOM BATHROOM SINK	0.185	TNR/BS
L6436062-68	CLINIC SINK	0.022	BS
L6436062-69	CLINIC SINK	0.129	BS
L6436062-70	CLASSROOM 8 FOUNTAIN	0.045	BS
L6479157-3	CLASSROOM 7 FOUNTAIN	0.135	BS
L6436062-72	CLASSROOM 18 FOUNTAIN	0.089	BS
L6436062-73	BOYS ROOM BY ROOM 7 SINK 1	0.123	TNR/BS
L6436062-74	CLASSROOM 11 SINK	0.005	TNR/BS
L6479157-4	CLASSRRROM 5 FOUNTAIN	0.138	BS
L6436062-76	ART ROOM BATHROOM SINK 2	0.012	TNR/BS
L6436062-77	SANDERS OFFICE	0.008	BS
L6436062-78	CLASSROOM 13 SINK	0.006	TNR/BS